



# R. V. BRIGGS & CO. PRIVATE LTD.

ANALYTICAL CONSULTING & TECHNICAL CHEMISTS

(AN ISO 9001:2015 & ISO 45001: 2018 CERTIFIED COMPANY)

TAHER MANSION, 1ST FLOOR

9, BENTINCK STREET, KOLKATA - 700 001

Phone : (033) 4044-3380/3381/3382 / 3383, Fax : 33 2248-0447

E-mail : rvbriggs.kolkata@gmail.com, Website : www.rvbriggs.com

CIN : U51109WB1931PTC007007



## TEST REPORT

ULR NO. TC781523100000683F

No. W(S)/22-23/1923

Date : February 06, 2023

Page 1 of 2

Issued to

: M/S. CAPRICANS AQUA PVT.LTD.

10, Madhusudan Das Bye Lane, Near Botanical Garden Post Office,  
Between liest 1st & 2nd Gate, Howrah-711103

Your Ref.

: E.mail dtd. 04.02.2023

Sample Description

: Drinking Water

Mark on Sample

: Treated Water IIM Hostel Dining

Sample Submitted On

: 04.02.2023

Test Completed on

: 05.02.2023

Parameters Tested:

Microbiological :

1) Coliform Organism (2) E.Coli

### Microbiological Test Findings :

Sl No.	Test parameters	Test Method	Unit	Result	Norms as per IS : 10500, 2012 (2nd Rev.), Amend., June 2015
1	Coliform Organism	APHA 23rd Edn. 9222B	CFU/100ml	Absent	Absent
2	E. coli	APHA 23rd Edn. 9222H	CFU/100ml	Absent	Absent

### Remarks on Microbiological Test Report :

The above mentioned sample of drinking water complies with IS: 10500, 2012 (2nd Rev.) & Satisfactory for drinking purpose, in respect of the above mentioned parameters

: END OF TEST REPORT :

Dr. S. Koruri

Authorized Signatory  
(I/C Microbiological Dept.)

- \* The test report shall not be reproduced, except in full, without written approval of the Company.
- \* Results relate only to the parameters tested.